



Because Everyone's Need Is Special

LEAD IN DRINKING WATER TESTING REQUIREMENTS IN THE STATE OF NEW JERSEY

EVERY THREE (3) YEARS, (FORMERLY EVERY (5) FIVE YEARS) ALL NEW JERSEY SCHOOLS ARE REQUIRED BY LAW TO PERFORM COMPREHENSIVE LEAD TESTING AT ALL EDUCATIONAL FACILITIES.

THE US GOVERNMENT HAS DETERMINED THAT THE MCL (MAXIMUM CONTAMINANT LEVEL) OF LEAD THAT IS PERMISSABLE IN DRINKING WATER IS 15 UG/L (MICROGRAMS PER LITER).

IN COMPLIANCE WITH ESTABLISHED LAW, ARCHWAY PROGRAMS COMPLETED TESTING AT ARCHWAY UPPER SCHOOL, AND AT ARCHWAY LOWER SCHOOL.

THE MOST RECENT FIVE YEAR ANNIVERSARY FOR LEAD TESTING AT ARCHWAY SCHOOLS OCCURRED IN JUNE OF 2022. THE NEXT THREE-YEAR COMPREHENSIVE LEAD TESTING OF DRINKING WATER AT OUR EDUCATIONAL FACILITIES WILL BE PERFORMED AGAIN IN THE SPRING OF 2025.

DURING THE LAST WEEK OF JUNE 2022, GARDEN STATE LABORATORIES, A NJ CERTIFIED/STATE APPROVED NEW JERSEY TESTING LABORATORY, PERFORMED LEAD TESTING AT RANDOMLY SELECTED ARCHWAY PROGRAM EDUCATIONAL DRINKING WATER OUTLETS.

WE ARE HAPPY TO REPORT THAT ALL OF OUR DRINKING WATER OUTLETS' LEAD CONTENT LEVELS FELL WELL BELOW THE MCL.

IN COMPLIANCE WITH PUBLIC REPORTING REGULATIONS, ALL GARDEN STATE LABORATORY RESULTS OF LEAD TESTING ARE ATTACHED.

Sample ID: Upper School - Girls RR By Room 4 Lab Sample ID: 220629052-09
 Site: Collection Date/Time: 06/28/2022 14:16
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/11/22 22:34	

Sample ID: Upper School - Boys RR By Room 4 Lab Sample ID: 220629052-10
 Site: Collection Date/Time: 06/28/2022 14:17
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/11/22 22:37	

Sample ID: Upper School - Girls RR L By Room 10 Lab Sample ID: 220629052-11
 Site: Collection Date/Time: 06/28/2022 14:19
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00195 mg/l	0.015	0.00100	0.00055	20044	07/11/22 22:40	

Sample ID: Upper School - Boys RR L By Room 10 Lab Sample ID: 220629052-12
 Site: Collection Date/Time: 06/28/2022 14:21
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/11/22 22:42	

Sample ID: Upper School - Kitchen RR Sink (Pantry) Lab Sample ID: 220629052-13
 Site: Collection Date/Time: 06/28/2022 14:24
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/11/22 22:45	



Sample ID: Upper School - Girls Cafe RR (Gym) Lab Sample ID: 220629052-14
 Site: Collection Date/Time: 06/28/2022 14:25
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00175 mg/l	0.015	0.00100	0.00055	20044	07/11/22 22:48	

Sample ID: Upper School - Boys Cafe RR (Gym) Lab Sample ID: 220629052-15
 Site: Collection Date/Time: 06/28/2022 14:27
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/11/22 22:51	

Sample ID: Upper School - Girls RR R by Room 10 Lab Sample ID: 220629052-16
 Site: Collection Date/Time: 06/28/2022 14:30
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/11/22 23:06	

Sample ID: Upper School - Boys RR R By Room 10 Lab Sample ID: 220629052-17
 Site: Collection Date/Time: 06/28/2022 14:32
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/11/22 23:14	

Sample ID: Upper School - Boys RR C By Room 10 Lab Sample ID: 220629052-18
 Site: Collection Date/Time: 06/28/2022 14:33
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00151 mg/l	0.015	0.00100	0.00055	20044	07/11/22 23:17	



