



SMITHCO. ENGINEERING GROUP, INC.

808 Market Street, Suite 336 • Camden, New Jersey 08102

Direct No. 609-682-0096 • www.smithcogroup.com

October 28, 2021

Mr. William Van Syckel
Facilities Director
Camden City Schools
901 S. 8th Street
Camden, NJ 08102

Dear Mr. Van Syckel:

THE SMITHCO ENGINEERING GROUP, INC. (SMITHCO) was authorized by the Camden Board of Education to undertake lead in water sampling at the at the following locations:

Catto	Yorkship
Coopers Poynt	CAMVA
Cream	Veterans
Davis	Camden High
Dudley	Brimm Medical
ECDC	Woodrow Wilson
Forest Hill	Central Office
HB Wilson	

Sampling was collected by a first draw second draw method. Samples were collected as a "**first draw**" after a minimum of six (6) hours of no water use. Our Scope of Work is detailed in the following pages.

It should be noted at **ALL SAMPLES were found to be None Detected or below the regulatory limits of 20 ppb except for two (2) locations. They are as follows:**

SCHOOL	LOCATION	RESULTS	RECOMMENDATIONS
RT Cream	Kitchen Sink	1 st Draw 7.07 ppb 2 nd Draw 25.5 ppb	Manually flush sink for two (2) minutes prior to usage or provide bottled water.
HB Wilson	Nurse's Office Sink	1 st Draw 24.9 2 nd Draw ND	Manually flush sink for two (2) minutes prior to usage or provide bottled water.

***SERVING OUR CLIENTS WITH A COMMITMENT TO
PARTNERSHIP, ALLIANCE, INFORMATION AND CORPORATE INTEGRITY***

Please see attached Sample Results. If you should have any questions or need further information, please do not hesitate to contact me at 609.682.0096.

Respectfully Submitted,

/s/ *Sean S. Smith*

Sean S. Smith, Sr., President

3.2.2 Cooper's Poynt:

Definitions

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

Analytical Results

Cooper's Poynt:

Client Sample Description 1 Kitchen Dish Sink **Collected:** 9/3/2021 6:33:00 AM **Lab ID:** 012110131-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/13/2021 VD	9/13/2021 17:29 VD

Client Sample Description 2 2nd Draw of 1 **Collected:** 9/3/2021 6:34:00 AM **Lab ID:** 012110131-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/13/2021 VD	9/13/2021 17:36 VD

Client Sample Description 3 Kitchen Hand Sink **Collected:** 9/3/2021 6:35:00 AM **Lab ID:** 012110131-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.5	1.00 µg/L	9/14/2021 KG	9/15/2021 16:28 JW

Client Sample Description 4 2nd Draw of 3 **Collected:** 9/3/2021 6:36:00 AM **Lab ID:** 012110131-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.06	1.00 µg/L	9/13/2021 VD	9/13/2021 17:38 VD

Client Sample Description 5 Nurse Sink **Collected:** 9/3/2021 6:39:00 AM **Lab ID:** 012110131-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/13/2021 VD	9/13/2021 17:39 VD

Analytical Results

Cooper's poynt:

Client Description	Sample 6 2nd Draw of 5	Collected: 9/3/2021 6:40:00 AM	Lab ID: 012110131-0006		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.32	1.00 µg/L	9/13/2021 VD	9/13/2021 17:41 VD
Client Description	Sample 7 Boys Bathroom Main Lobby	Collected: 9/3/2021 6:43:00 AM	Lab ID: 012110131-0007		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.35	1.00 µg/L	9/13/2021 VD	9/13/2021 17:42 VD
Client Description	Sample 8 2nd Draw of 7	Collected: 9/3/2021 6:44:00 AM	Lab ID: 012110131-0008		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.46	1.00 µg/L	9/13/2021 VD	9/13/2021 17:43 VD
Client Description	Sample 9 Girls Bathroom Main Lobby	Collected: 9/3/2021 6:46:00 AM	Lab ID: 012110131-0009		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/13/2021 VD	9/13/2021 17:45 VD
Client Description	Sample 10 2nd Draw of 9	Collected: 9/3/2021 6:47:00 AM	Lab ID: 012110131-0010		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/13/2021 VD	9/13/2021 17:46 VD

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results