



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Manager Emerita

For: Archway School - JM
280 Jackson Road

Atco, NJ 08004

Laboratory Director:

Attention: Mike Smalley

Client Number: ARC01

Report Date: 12/02/2025

Sample ID: Lab Sample ID: 251112088-01 PWSID Number: NJ0313300
Site: DS - Upper - Kitchen Sink Collection Date/Time: 11/12/2025 12:02 Facility ID: DS
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Free Chlorine, Residual	SM 4500Cl-G	11	1	< 0.0500 mg/l	4	0.0500	0.02	15037	11/12/25 12:03	
Heterotrophic Plate Count	SM 9215 B	04	1	< 5 CFU/100ml	500	5		15037	11/12/25 15:50	
E. coli	SM 9223 B Colilert 18	04	1	Absent per 100ml	Absent	1		15037	11/12/25 15:50	
Total Coliforms	SM 9223 B Colilert 18	04	1	Absent per 100ml	Absent	1		15037	11/12/25 15:50	

Sample ID: Sink Lab Sample ID: 251112088-02 PWSID Number: NJ0313300
Site: POE-Upper-Old Teachers Lounge/Classroom 9 Collection Date/Time: 11/12/2025 11:54 Facility ID: WL001003
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Chromium, Total Recoverable	EPA 200.7		1	< 0.00400 mg/l	0.1	0.00400	0.00116	20044	11/19/25 17:41	
Arsenic, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.005	0.00100	0.00026	20044	11/17/25 15:13	
Barium, Total Recoverable	EPA 200.8		1	0.00660 mg/l	2	0.00100	0.0003	20044	11/25/25 12:30	
Cadmium, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.005	0.00100	0.00014	20044	11/17/25 15:13	
Selenium, Total Recoverable	EPA 200.8		1	< 0.00300 mg/l	0.05	0.00300	0.00152	20044	11/17/25 15:13	
Antimony, Total Recoverable	EPA 200.8		1	< 0.000400 mg/l	0.006	0.000400	0.00024	20044	11/17/25 15:13	
Beryllium, Total Recoverable	EPA 200.8		1	< 0.000300 mg/l	0.004	0.000300	0.00015	20044	11/17/25 15:13	
Nickel, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l		0.00100	8E-05	20044	11/17/25 15:13	
Thallium, Total Recoverable	EPA 200.8		1	< 0.000300 mg/l	0.002	0.000300	0.00024	20044	11/17/25 15:13	
Mercury	EPA 245.1		1	< 0.000200 mg/l	0.002	0.000200	7E-05	20044	11/17/25 15:14	
Nitrate/Nitrite	Lachat 10-107 -04-1-A		1	< 0.0500 mg/l	10	0.0500	0.02	20044	11/13/25 06:49	
Sodium	SM 3111B	19	10	4.96 mg/l	50	1.00	0.7	20044	11/20/25 14:00	
Cyanide	SM 4500 Cn-E		1	See attached mg/l				15083	11/19/25 12:00	
Fluoride	SM 4500 F-C	21	1	0.0850 mg/l	4	0.0500	0.01	20044	11/19/25 05:33	